

CERTIFICATE OF COMPLIANCE

Certificate Number 20140403-E189035
Report Reference E103582-19950216
Issue Date 2014-APRIL-04

Issued to: HIMEL METAL DISTRIBUTION BOX

**This is to certify that
representative samples of**

WENZHOU CITY TJ ELECTRIC APPLIANCES CO. LTDA
Industrial Control Equipment Enclosures Types CRN or
NSYCRN (Spacial CRN Series) and CRS followed by a
reference number with or without Suffix KT or T.

Single door enclosures having a max height of 2000 mm
and a width of 800 mm are rated Type 1, 2, 3, 3R, 4, 5, 12
and 13.

Double Door enclosures 1000 to 1600 mm wide are rated
Type 1, 12 and 13.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:


UL 508A, Industrial Control Panels
CSA C22.2 NO. 14, Industrial Control Equipment

Additional Information:


See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and

"US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

